

# **EMERGENCY RESPONSE TO CONSTELLATION AND ENTERGY NUCLEAR POWER PLANTS**

## **Purpose:**

- To establish the operating procedures related to responding to the townships three nuclear power facilities both inside and outside the secure areas.

## **Guideline for Fires Outside the Secure Area:**

- Fires outside the secure area are the responsibility of this agency and will be handled in accordance with the departments established SOG's

## **Guidelines for Fires Inside the Secure Area (on-site)**

- Apparatus will respond as per the Alarm Response Card
- No member or mutual aid member will be allowed on the plant unless they enter on an emergency vehicle – No exceptions
- On arrival at the first Chief or Officer will establish a joint command post with the Site Fire Chief
  - Site Fire Chief is responsible for operations with-in the power block and Scriba Command will coordinate incoming apparatus and personnel
  - Fires not involving the power grid may be handed over to Scriba Command (Admin Buildings / Warehouse)
  - Only one County Coordinator will be allowed on-site to assist the incident commanders.
- If a working fire is confirmed activate the second alarm companies and stage for use
  - Primary Staging is unit parking Lot
  - During in climate weather consider the Fire Station
- When fire involves the power block try as soon as possible to relieve the fire brigade members with SVFD personnel and use fire brigade members as escorts.
- Ensure personnel accountability at all times and have a minimum of a four person RIT Team with an escort available.

## **Guidelines for Possible or Actual Terrorist Event (Hostile Takeover)**

- When possible the 911 Center will activate the SVFD and have members report to the Station and Call the 911 Center for information related to and give the plant name.
  - This is an indicator of potential terrorist type incident at the plant and all members are encouraged to use caution approaching the station and stay away if things do not look appropriate (Call 911)
  - Remember the plant may be a primary attack site and SVFD could be used as a diversionary attack or to steal apparatus
- If notification is of an armed conflict at Nine Mile 1 or 2 2761, 2762 and the Ambulance should be staged at Cliff Rd and CR 1A
- If notification is for an armed conflict at Entergy 2761, 2762 and the Ambulance should be staged at Minor Rd and CR 29

- No Response should be made into the plant until cleared by the Oswego County Sheriffs Dept this is without exception OCSO is lead agency.
- If multiple injured parties are identified follow the established Mass Casualty Plan
- Remember to preserve as much evidence as possible and have either police or security secure any weapons found.
- Leave Terrorists alone until cleared by Police (Secondary Explosives)

#### **Guideline for Potential / Actual Aircraft Attack (B5B)**

- In the event of a possible aircraft attack on the facilities the plants will attempt to give us as much warning as possible although the target time is 10 minutes
- The 911 Center will activate the SVFD and have members report to the Station and Call the 911 Center for information related to and give the plant name.
  - This is an indicator of potential terrorist type incident all members are encouraged to use caution approaching the station and stay away if things do not look appropriate and call 911 from another location
  - Remember the plant may be a primary attack site and SVFD could be used as a diversionary attack or to steal apparatus
- Have 911 activate for 171 and Volney for the airport crash truck and have them staged at the Scriba Station
- No response to the plants until an actual crash has occurred
  - Consider staging at Lake Rd and CR 1 as this will allow access to all plants
  - Ensure Oswego Ambulance is aware of the situation due to potential mass casualty incident
- Follow department alarm response card and move up companies as needed
- Remember that we have an extremely limited supply of foam and application equipment use it wisely, life hazard is the first priority
- The Plants fire brigade will be concerned with protection of the power block and command must ensure they have the necessary resources before concern with injuries or other parts of the plant.
- If Mass Casualty Incident exists follow the mass casualty plan and best case scenario may just be to move people rapidly off-site for triage and treatment.
- Due to lack of foam capabilities utilize large stream appliances and where possible a defensive attack.
- If site Hydrants are inoperable establish draft sites at the cooling tower for Nine Mile 1 & 2 and at the water intake at the northeast corner of Entergy passing supply lines thru the fence. (This has been approved thru fire protection)

#### **Guideline for EMS Response if requested**

- If request is for a medical emergency (heart attack / stroke) 2762 will respond and be the only unit on site.
- If the alarm involves entrapment, confined space, injury from a fall, or cannot be determined at time of call 2761 will respond first followed by 2762.

**Scriba Volunteer Fire Department**  
**Alarm Response**

**ZONE # 7**

**All Nuclear Power Plants and Associated Structures**  
**SITHE Plant – Independence Station**  
**Alcan Aluminum**

**FIRST ALARM**

Scriba 2741  
2742  
2761  
111 – Novelis 0600 –1600  
Ambulance Standby  
38MC1 – Mexico

**SECOND ALARM**

1641 – New Haven  
1511 – Minetto  
2843 – Volney

**THIRD ALARM**

3441 – Oswego Town  
1643 – New Haven  
1461 - Mexico

**STATION COVER**

1641 – New Haven

**STATION COVER**

3441 – Oswego Town

**STATION COVER**

2842 – Volney

**WATER SUPPLY**

Facilities Hydrants

**LADDER TRUCKS**

<b><u>LADDER TRUCKS</u></b>	<b><u>ETA</u></b>
181 – Novelis – 100 ‘ Ladder – no pump	10 min
1813 – Oswego City 75” Quint	20 min
381 – Fulton City – 102’ Tower	35 min
382 – Fulton City – 100’ Ladder	35 min
2381 – Pulaski 105’ Tower	45 min
2080 – Parish 100’ Ladder	55 min
4781 – Phoenix 75’ Quint	60min